



### Blended Fuel Compatibility Form

Facility - 2047042

**Facility Name** Love's Travel Stop #768  
**Address** 23815 W. Bluff Rd.  
 Channahon, IL 60410  
**County** Will  
**Contact Name** Brad Whitler  
**Phone Number** (815) 860-6641

Tank - 2

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 12,000  
**Tank Install Date** 6/26/2020  
**Current Product on File** Gasoline - Regular  
**Newly Reported Product** E98

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	XERXES E98 COMPATABLE UST UGPetroleumStorageTankWa rr.5.1.2019 B99 & E85.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	NOV E98 COMPATIBLE Red Th read IIA Piping Compatibl e Fuels B99 & E85.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern._Fuel_and_Fuel_Comp._Statement_PE_Stamped_2024.pdf	
Blending Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern._Fuel_and_Fuel_Comp._Statement_PE_Stamped_2024.pdf	
Single Wall UDC Sump	Bravo UDC	Manufacturer Approval	BRAVO Altern._Fuel_and_Fuel_Comp._Statement_PE_Stamped_2024.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling FMP-E1S	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
ATG Probe	Franklin Fueling - FMP-LL3-125-1	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling Systems - INC TS-ELLD	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Franklin Fueling Systems - FMP-ULS	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling - EBW L 708556901	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Franklin Fueling - INC TS-RA1	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
Overfill Drop Tube Valve	Franklin Fueling - EBW L 708692922	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling - FEP L 402568924-2HP	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Seals / Gaskets	Viton	Manufacturer Approval	Viton.pdf	

### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dope	Gasoil	Manufacturer Approval	Gasoil+-+E+seal+E20.pdf	

### Correspondence Contact

**Submitter Name** Anthony Mannino  
**Job Title** Project Manager  
**Company** Illinois Oil Marketing Equipment  
**Phone Number** (309) 369-0574  
**Email** amannino@iome.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.