



### Blended Fuel Compatibility Form

Facility - 2014582

Tank - 13

<b>Facility Name</b>	Midwest Convenience, Inc.	<b>Tank Material</b>	Fiberglass Double Wall
<b>Address</b>	499 W. Boughton Bolingbrook, IL 60440	<b>Tank Capacity</b>	4,000
<b>County</b>	Will	<b>Tank Product</b>	E85
<b>Contact Name</b>	Eric Schuermann	<b>Tank Install Date</b>	5/25/2006
<b>Phone Number</b>	(847) 407-9345		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	499 E 85.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	499 E 85.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	opw tank sumps and Franklin UDC. See 499 E 85 pdf for opw as it wont let me add another file	Manufacturer Approval	e85 franklin all.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	e85 probe.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	499 E 85.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	499 E 85.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	499 E 85.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Emco Wheaton	Manufacturer Approval	E85 Emco.pdf	Replacing - Single Wall Spill Bucket from Permit Application.

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Emco	Manufacturer Approval	E85 Emco.pdf	Replacing - Overfill Drop Tube Valve from Permit Application.

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco	E700 S	Manufacturer Approval	499 E 85.pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Correspondence Contact

**Submitter Name** Steve Kryl  
**Job Title** Project manager  
**Company** Anderson Pump Service  
**Phone Number** (708) 243-9081  
**Email** steve@andersonpump.com  
**Contractor License #** IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.