



### Blended Fuel Compatibility Form

<b>Facility - 5040225</b>		<b>Tank - 7</b>	
<b>Facility Name</b>	Mr. Fuel #1245	<b>Tank Material</b>	Composite Double Wall
<b>Address</b>	4th Corvette Drive Litchfield, IL 62056	<b>Tank Capacity</b>	20,000
<b>County</b>	Montgomery	<b>Tank Product</b>	B-99
<b>Contact Name</b>	Joey Cupp	<b>Tank Install Date</b>	3/26/2020
<b>Phone Number</b>	(865) 588-7488		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Composite Double Wall	Containment solutions	Manufacturer Approval	biofuel-compatibility.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	Franklin Fueling 662500202	Manufacturer Approval	Franklin Fueling 662 Series Shear Valve.pdf	From Permit Application
Piping - Fiberglass Double Wall Ameron Dualoy 3000/L	Ameron Dualoy 3000/L	Manufacturer Approval	Dualoy 3000 LCX Data Sheet (1).pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	OPW	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	
Under Dispenser Containment	Franklin Fueling APT	Manufacturer Approval	Franklin Fueling FFS-0390 Large Mouth Polyethylene Dispenser Sumps Datasheet.pdf	
Transition/ Blending Sump	Painted Rhino NEF Sump	Manufacturer Approval	Painted Rhino Bio Sump Compatibility.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensor	Veeder Root 794380-345	Manufacturer Approval	794380-345 Interstitial Sensor.pdf	
Mag Probe	Veeder Root 846391-109	Manufacturer Approval	Veeder Root Bio Compatible MAG and Sump Sensor.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Piping Tank Top Sensor	Veeder Root 794380-321	Manufacturer Approval	794380-321 Solid-State - Non - Discriminating Sump Pan Sensor.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Double Wall Spill Bucket	OPW 1C-3112D	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	

**Overfill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Drop Tube Valve	OPW 71SO-410CB	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	

**Pump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp GHS2JP3-B / S1	Manufacturer Approval	Gorman Rupp Bio Compatibility.pdf	

**Gaskets & Seals Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
No documentation submitted - Not required for tanks install prior to 10/13/2018	Gorman Rupp	Manufacturer Approval	Gorman Rupp Bio Compatibility.pdf	No documentation submitted - Not required for tanks install prior to 10/13/2018

**Joint Dopes & Adhesives Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
No documentation submitted - Not required for tanks install prior to 10/13/2018	Gorman Rupp	Manufacturer Approval	Bio Compat Letter.pdf	No documentation submitted - Not required for tanks install prior to 10/13/2018

**Correspondence Contact**

**Submitter Name** Skip Aulgur  
**Job Title** Estimator  
**Company** Neumayer Equipment Company, Inc.  
**Phone Number** (314) 497-9884  
**Email** skip\_aulgur@neumayerequipment.com  
**Contractor License #** IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.