



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2046491

Facility Name Lenny's Food N Fuel Vetter
Road, LLC
Address 2951 CenterPoint Way
Elwood, IL 60421
County Will
Contact Name Marcellia Rush
Phone Number (779) 230-6850

Tank - 6

Tank Material Fiberglass Brine Filled Double
Wall
Tank Capacity 10,000
Tank Product B-99
Tank Install Date 4/5/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Lab Certification	Containment Solutions.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump North	Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Bravo	Lab Certification	Bravo Sumps.pdf	
Blending Sump South	Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall UDC Sump	Bravo	Lab Certification	Bravo FRP sump retro.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-304	Manufacturer Approval	compat B100.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Lab Certification	Letters of Compability up to B100.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Blending Sump North	Veeder Root	Lab Certification	Letters of Compability up to B100.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Lab Certification	Letters of Compability up to B100.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Blending Sump South	Veeder Root	Lab Certification	Letters of Compability up to B100.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling	Lab Certification	Defender Bio.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw	Lab Certification	Opw Bio 5 to 100.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Stp	Fe petro	Lab Certification	Fe Petro Subs.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Stephen Kryl

project manager

Anderson Pump Service

(708) 243-9081

Steve@andersonpump.com

IL002275

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.