



### Blended Fuel Compatibility Form

<b>Facility - 2034044</b>		<b>Tank - 3</b>	
<b>Facility Name</b>	Thornton's #117	<b>Tank Material</b>	Fiberglass Single Wall
<b>Address</b>	900 N. La Fox Street South Elgin, IL 60177	<b>Tank Capacity</b>	12,000
<b>County</b>	Kane	<b>Tank Product</b>	E-85
<b>Contact Name</b>	Scott Roberts	<b>Tank Install Date</b>	6/6/1995
<b>Phone Number</b>	(502) 425-8022		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval	Containment Solut...	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flex Connector Steel	Hose Master	Manufacturer Approval	flexibleconnector...	From Permit Application
Fiberglass Single Wall Piping	Ameron Fiberglass	Manufacturer Approval	Ameron Piping.pdf	From Permit Application
Shear Valves	OPW	Manufacturer Approval	OPW Shear Valve.p...	From Permit Application

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	Containment Solut...	
Single Wall Dispenser Sump	Bravo B-1000	Manufacturer Approval	Bravo Dispenser S...	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-407	Manufacturer Approval	Veeder Root Probe...	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	Veeder Root Elect...	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling Defender	Manufacturer Approval	Franklin Fueling ...	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	OPW 53VML	Manufacturer Approval	53VML_30MV_Ball_F...	
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	OPW Overfill Prev...	

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling ISTMVS4-VL2	Manufacturer Approval	FE Petro Submersi...	

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Nick Bugajsky  
**Job Title** Project Manager  
**Company** Stenstrom Petroleum Services Group  
**Phone Number** (708) 485-4105  
**Email** nickb@rstenstrom.com  
**Contractor License #** IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.