

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 3035590

Facility Name Homecity Express
Address 365 US Hwy 6 East
 Geneseo, IL 61254
County Henry
Contact Name Dhaval Vakharia
Phone Number (330) 979-2110

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 5/15/1997

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Fluid Containment	Manufacturer Approval	CSIALcoholcompati...	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S150SC	Manufacturer Approval	ffs-0524-xp-flexi...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Adding New TSM 4736 tank sump New APT LMM3617 Dispenser sump	Manufacturer Approval	FFS-0691 UL 2447 ...	Environ is no longer in business but we plan to add sump sensor and repipe out 0...

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-323	Manufacturer Approval	HomecityVRsensor...	
ATG Probe	Veeder Root 846396-107	Manufacturer Approval	VR-577014-449-08_...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Manufacturer Approval	HomecityVRsensor...	From Permit Application
Mechanical Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	VR PLLD Applicati...	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-208	Manufacturer Approval	VR Sensor Applica...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW-70549202blk	Lab Certification	FFS-0691 UL 2447 ...	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW-708691921 Defender overfill	Manufacturer Approval	FFS-0691 UL 2447 ...	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pressurized Dispenser with OPW E85 nozzle, OPW break-a-way swivel , Husk	FE Petro STP75AG variable length sub pump	Manufacturer Approval	FFS-0796 Submersi...	The Gilbarco Dispenser is also UL approved Encore 700s

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Art INC.

Job Title sales

Company Pipeco, Inc.

Phone Number (563) 529-8494

Email art@pipecoinc.com

Contractor License # IL2034

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.