

**Blended Fuel Compatibility Form**

Facility - 2022185

Facility Name Thornton's #113
Address 9138 S. Cicero Ave.
Oak Lawn, IL 60453
County Cook
Contact Name Daisy Quiroga
Phone Number (708) 229-0708

Tank - 9

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 7/22/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions Double Wall with Brine	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	3+Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo	Manufacturer Approval	4+UDC+Bravo.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions SW Fiberglass Tank Sumps	Manufacturer Approval	2 +Tank+Sumps+CSI.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	5+Probe+Float.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-003	Manufacturer Approval	7+E85+Compatibility+TLS+Products.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling Defender 705	Manufacturer Approval	8+Spill+Bucket+Franklin.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	9+Overfill+Prevention+Valve+OPW.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump	Franklin Fueling IST	Manufacturer Approval	10+Pump+Franklin.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Amber Pena

Director of Service

Stenstrom Petroleum Services Group

(815) 398-6250

amberp@rstenstrom.com

IL1890

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.