

**Blended Fuel Compatibility Form**

Facility - 2021476

Facility Name Rockbuild Enterprises, Inc.
d/b/a Kedzie Auto Service
Address 5301 S. Kedzie
Chicago, IL 60632
County Cook
Contact Name Mohammad Khan
Phone Number (312) 685-7363

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Install Date 5/18/2022
Current Product on File Diesel Fuel
Newly Reported Product E85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double wall Fiber Glass	Containment Solutions Inc	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW-Emergency Shutt off valve-10P Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall -UDC	Bravo-B700 series	Manufacturer Approval		New from Permit Application.
Single Wall STP/Tanktop Sump	Bravo Containmnet	Manufacturer Approval		
Single Wall UDC Sump	Bravo UDC	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root-846397-407	Manufacturer Approval		New from Permit Application.
Interstitial Sensor for alternate fuels	Veeder Root-794380-345	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Leak Detector	Veeder Root-8480-001	Manufacturer Approval		
Non Discriminating Sump Sensor	Veeder Root-794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-2100 Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling-STPAG Series	Manufacturer Approval		
Dispenser	Gilbarco Encore-700 Series	Manufacturer Approval		
Nozzle	opw-11BP-0992-E85	Manufacturer Approval		
Hose	Continental Conintech- E85	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets and Seals -Tanks	Containmnet Solutions Inc	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope for all pipes	Gasola	Manufacturer Approval		

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company Ampsco services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.