



Blended Fuel Compatibility Form

Facility - 4034390

Facility Name	ML & RJ, Inc.
Address	10 E. Northbrook Dr. Dwight, IL 60420
County	Livingston
Contact Name	Jennifer Powell
Phone Number	(815) 584-2189

Tank - 4

Tank Material	Composite Double Wall
Tank Capacity	10,000
Tank Product	E-85
Tank Install Date	1/9/2003

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall	Modern Welding Company Glasteel II UL58 & UL 1746	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	APT P-175SC Double Wall Flex	Manufacturer Approval		
Shear Valves	OPW 10R Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT TSM 4736 Single Wall Poly Sump	Manufacturer Approval		This does not normally contain blended fuel
Dispenser UDC's	APT LMM-7811 Single Wall Poly Sump	Manufacturer Approval		This does not normally contain blended fuel

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-430	Manufacturer Approval		
ATG Probe	Veeder Root 846391-107	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-352	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Defender Series 705-545-001 CI-GKT	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling 708-592-922	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Nozzles	OPW 11BP-0992-E85	Manufacturer Approval		
Pump Hose Swivels	OPW 241TPS-0492	Manufacturer Approval		
Safety Breakaway	OPW 66V-0492	Manufacturer Approval		
Pump Hoses & Whip Hoses	FLXE 200800 FLXE200009	Manufacturer Approval		
Fuel Dispenser	Dresser Wayne	Manufacturer Approval		
Submerged Turbine Pump	3/4 HP AG STP Red Jacket	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
E-Seal	Gasola E-Seal	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
E-Seal	Gasola E-Seal	Manufacturer Approval		

Correspondence Contact

Submitter Name Butch VonDrehle
Job Title Owner
Company Pemco Service Co., Inc.
Phone Number (815) 265-7364
Email pemcogilman@sbcglobal.net
Contractor License # IL1224

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.