

**Blended Fuel Compatibility Form****Facility - New**

Facility Name QuikTrip #4437
Address 750 W 172nd Street
South Holland, IL 60473
County Cook
Contact Name Kyla Rudd
Phone Number (918) 655-7700

Tank - 4

Tank Material Tank - Fiberglass Brine Filled
Double Wall XERXES
Tank Capacity 15,000
Tank Product E15
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Tanks.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	OPW+Compatibility+Matrix.pdf	New from Permit Application.
Flex Connector Steel	Hose Master	Manufacturer Approval	Hosemaster+Flex+Connectors.pdf	New from Permit Application.
Shear Valves	OPW 10 Plus Series	Manufacturer Approval	OPW+Compatibility+Matrix.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	PCI	Manufacturer Approval	PCI+Sumps.pdf	New from Permit Application.
Single Wall Transition Sump	PCI	Manufacturer Approval	PCI+Sumps.pdf	New from Permit Application.
Dispenser Containment Sumps	Bravo	Manufacturer Approval	Bravo Dispenser Sump.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-303	Manufacturer Approval	Veeder+Root+Sump+&+Interstitial+Sensors (1).pdf	New from Permit Application.
ATG Probe	Veeder Root 846397-609	Manufacturer Approval	Veeder+Root+Probe+&+Float (1).pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Manufacturer Approval	VR+PLLD+Fuel+Compatibility.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 794380-208	Manufacturer Approval	Veeder+Root+Sump+&+Interstitial+Sensors (1).pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-31100	Manufacturer Approval	OPW+Compatibility+Matrix.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling 708592922	Manufacturer Approval	FFS-0392+Defender+Series+OPV+Datasheet.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro	Manufacturer Approval	FE+Petro+Submersible+Pump.pdf	
Dispenser	Gilbarco	Manufacturer Approval	Gilbarco+Dispenser+Compatibility.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Gilbarco	Manufacturer Approval	Gilbarco+Dispenser+Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola	Manufacturer Approval	Gasola.pdf	

Correspondence Contact

Submitter Name Nick Bugajsky
Job Title Project Manager
Company Stenstrom Petroleum Services Group
Phone Number (630) 606-0996
Email nickb@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.