



Blended Fuel Compatibility Form

Facility - 2041452		Tank - 3	
Facility Name	Alpha Gas Mart	Tank Material	Composite Double Wall
Address	810 W. 59th Street Chicago, IL 60621	Tank Capacity	5,000
County	Cook	Tank Install Date	12/6/2002
Contact Name	Nizar Assaf	Current Product on File	Diesel Fuel
Phone Number	(773) 783-3910	Newly Reported Product	E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel Double wall	Manufacturer Approval	Glasteel II BioFuels Compatibility 2018.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Environ Geo Flex	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Pages 8 and 10
Shear Valve	OPW 10P-0152E85	Manufacturer Approval	opw all products.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Environ	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Top of page 5
Single Wall UDC Sump	Environ	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Top of page 5

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846397-407	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	Veeder-Root PLLD.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1C-2100-DEVR	Manufacturer Approval	Opw spill containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	71SOM_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin 402018905/Stpag75-vl2-00	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne Ovation 2	Manufacturer Approval	Wayne Ovation EB23.pdf	
Nozzle	Opw 11bp 400691766	Manufacturer Approval	opw-11bp-series-ethanol-n ozzles_2018.pdf	
Hose	Opw 24tpps	Manufacturer Approval	opw-241tps-series-hose-sw ivels_2018.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Darren White
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 474-3344
Email dj.white@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.