



Blended Fuel Compatibility Form

Facility - 6043651

Facility Name	Pilot Travel Center #1219
Address	10 Interstate Drive Vandalia, IL 62471
County	Fayette
Contact Name	Joey Cupp
Phone Number	(865) 588-7488

Tank - 6

Tank Material	Fiberglass Double Wall
Tank Capacity	20,000
Tank Product	B-99
Tank Install Date	7/19/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Piping/Tanktop Sump	Petroleum Containment, Inc	Manufacturer Approval		
Blending Sump	Petroleum Containment, Inc	Manufacturer Approval		
Single walled Bioheater Tank Top Sump	Petroleum Containment, Inc.	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-345	Manufacturer Approval		
ATG Probe	Veeder Root / 846391 Mag Plus Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root / 0857080-111	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown Blending Sump	Veeder Root / 0794380-321	Manufacturer Approval		
Bio-heater Tank Top Sump	Veeder Root / 794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW / 71SO-410CB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Fittings	NOV Ameron / Fittings	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Glue	NOV Ameron / Psx-20 Piping Glue	Manufacturer Approval		

Correspondence Contact

Submitter Name Brian Niederschmidt

Job Title Estimator

Company Neumayer

Phone Number (636) 515-4517

Email brian_niederschmidt@neumayerequipment.com

Contractor License # IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.