

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Lenny's Gas N Wash North
Aurora, LLC
Address 230 Airport Road
North Aurora, IL 60542
County Kane
Contact Name Leonard McEnergy
Phone Number (708) 444-0117

Tank - 3

Tank Material Tank - Fiberglass Double Wall
XERXES
Tank Capacity 10,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	e85 xerxes.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass Dualoy 3000/LCX	Manufacturer Approval	e85 frp pipe.pdf	New from Permit Application.
Other Riser	Steel	Lab Certification	E85 equipment approvals U S Department of Energy.pdf	New from Permit Application.
Flex Connector Steel	Fire Shield	Manufacturer Approval	e85 -hosemaster.pdf	New from Permit Application.
Shear Valves	opw 10p	Manufacturer Approval	e85 opw all.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	e85 bravo.pdf	New from Permit Application.
udc	Bravo B1000	Manufacturer Approval	e85 bravo.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794380-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.
Non-Discriminating Interstitial Monitoring Sensors	veeder Root 794380-323	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root PLLD	Manufacturer Approval	e85 plld.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 794380-323	Lab Certification	E85 sensors.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin	Manufacturer Approval	e85 franklin spill.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	e85 drop tube.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispenser	E700S	Manufacturer Approval	e85 gilbarco.pdf	
Submersible Turbine Pump	Franklin	Manufacturer Approval	e85 franklin all.pdf	
Nozzle	OPW	Manufacturer Approval	e85 opw all.pdf	
Hose	Contental	Lab Certification	e85 contental hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None that are not part of an approved assembly.	NA	Not Applicable		None that are not part of an approved assembly.

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoil	Manufacturer Approval	e85 dope.pdf	

Correspondence Contact

Submitter Name Stephen M Kryl
Job Title Project Manager
Company Anderson Pump Service, Inc.
Phone Number (708) 243-9081
Email Steve@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.