



Blended Fuel Compatibility Form

Facility - 2038827

Facility Name 63rd and Drexel Building LLC
Address 840 - 850 E. 63rd Street
 Chicago, IL 60637
County Cook
Contact Name Howard Wietzman
Phone Number (312) 913-9953

Tank - 5

Tank Material Fiberglass Single Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 7/27/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes	Manufacturer Approval		
Single Wall Dispenser Sump	Xerxes	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-323	Manufacturer Approval		
ATG Probe	Veeder Root 847391-107	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro STP MLD+G	Manufacturer Approval		
Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Nozzle	OPW 11BPE85	Manufacturer Approval		
Hoses	Continental	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name	Tom Stoll	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title	Owner	
Company	Big Daddy Pump Co	
Phone Number	(610) 505-7154	
Email	Bigdaddypumpco@gmail.com	
Contractor License #	IL002427	