



Blended Fuel Compatibility Form

Facility - New		Tank - 5	
Facility Name	QuikTrip #7195	Tank Material	Tank - Fiberglass Brine Filled Double Wall XERXES
Address	415 N Swift Road Addison, IL 60101	Tank Capacity	18,000
County	Du Page	Tank Product	B-99
Contact Name	Kyla Rudd	Tank Install Date	Not Installed
Phone Number	(918) 655-7700		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Tanks and Sumps.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0164 UPP Semi-Rigid P ipework System Datasheet. pdf	From Permit Application
Flex Connector Steel	Franklin Fueling Systems	Manufacturer Approval	Flexible Connectors Datasheet.pdf	From Permit Application
Shear Valves	OPW	Manufacturer Approval	opw-10-plus-series-emergency-shut-off-valves-2018. pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	From Permit Application
Single Wall STP/Tanktop Sump	PCI	Manufacturer Approval	PCI-BioDiesel.pdf	From Permit Application
Single Wall Transition Sump	PCI	Manufacturer Approval	PCI-BioDiesel.pdf	From Permit Application
Single Wall Dispenser Sump	Bravo B-1000	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-304	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	From Permit Application
ATG Probe	Veeder Root 846391-109	Manufacturer Approval	Veeder Root Probe Biodiesel Approval Letter.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	PLLD VR859080-001.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-321	Manufacturer Approval	794380-321.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100 Series (Edge)	Manufacturer Approval	OPW Compatibility Matrix.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root	Manufacturer Approval	Veeder Root Probe Biodiesel Approval Letter.pdf	From Permit Application
Overfill Drop Tube Valve	Franklin Fueling Systems 708592922	Manufacturer Approval	708592922 Overfill protection defender series Bio compatible cut sheet.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling Systems	Manufacturer Approval	FFS-0796 Submersible Turbine Pumps Datasheet.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Total Control Systems	Manufacturer Approval	682-15-engineering-manual .pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolia	Manufacturer Approval	Gasolia.pdf	

Correspondence Contact

Submitter Name Nick Bugajsky
Job Title Project Manager
Company Stenstrom Petroleum Services Group
Phone Number (740) 848-5410
Email nickb@rstenstrom.com
Contractor License # IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.