

**Blended Fuel Compatibility Form**

Facility - 4007142

Facility Name Circle K #1404
Address 1212 North Bowman
Danville, IL 61832
County Vermilion
Contact Name April Grimes
Phone Number (217) 431-3750

Tank - 7

Tank Material Fiberglass Brine Filled Double
Wall
Tank Capacity 4,000
Tank Product E85
Tank Install Date 11/14/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	CompatibilityFormSummary06062022-095553.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron (Aka NOV) / LCX	Manufacturer Approval	Dualoy 3000 LCX Data Shee t.pdf	6/6/22 uploaded documentation for LCX piping. See description section for compa...

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP Sump	Containment Solutions	Manufacturer Approval	containment+solutions+bio fuel-compatibility+(3).pd f	
Dispenser Sump	OPW poly sump	Manufacturer Approval	opw-fuel-compatibility-ma trix-below-ground-product s-2018.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 864391-404	Manufacturer Approval	846391-xxx Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	794380-303 Dual-Point Hyd rostatic Reservoir Sensor (brine Filled_Double_Wal l_Tank_Sensor.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP Sump Sensor	Veeder Root / 794380-351	Manufacturer Approval	Veeder Root 794380-351 B1 00 Compatible.pdf	
Under dispenser containment leak detection	Veeder Root / 794380-321	Manufacturer Approval	Non Discriminating Dispenser Pan Sensor 794380-321 .pdf	
Mechanical Pressurized Line Leak Detection	Red Jacket 116-056-5	Manufacturer Approval	Red+Jacket@+FXV+Series+Mechanical+Line+Leak+Detect ors+_+Veeder-Root.pdf	
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / 794380-351	Manufacturer Approval	Veeder+Root+794380-351+B1 00+Compatible.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW Tank Equipment Compatibility.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Gilbarco Advantage	Manufacturer Approval	FW_ LPM-101E.pdf	The Advantage dispenser has a Liqua-Tech LPM-101E meter for Ethanol.

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Larry Russell

Job Title HM Lead

Company JF Acquisition, LLC d/b/a
Jones & Frank

Phone Number (618) 419-5081

Email Scot.russell@jfpetrogroup.com

Contractor License # IL002422

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.