



Blended Fuel Compatibility Form

Facility - 4006082

Tank - 4

Facility Name	South Central FS, Inc. - Windsor	Tank Material	Fiberglass Double Wall
Address	1520 Kentucky Avenue Windsor, IL 61957	Tank Capacity	4,000
County	Shelby	Tank Product	E-85
Contact Name	Stanley Joergens	Tank Install Date	11/13/2013
Phone Number	(217) 342-9231		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		
Shear Valves	EBW 662 with E-Coating	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions SW Fiberglass	Manufacturer Approval		
Single Wall UDC	APT LMM 3617	Manufacturer Approval		Dispensers 1,2-3,4

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 0749380-345	Manufacturer Approval		
ATG Probe	Veeder Root 846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root PLLD	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		Tanktop Sump and UDCs 1,2-3,4

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 GL W/ DPM Liner kit	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root 790091-001/790095-001	Manufacturer Approval		Does not normally come in contact with Fuel
Ball Float Vent Valve	OPW 53	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fuel Dispensers	Gilbarco E700S Flex Fuel	Manufacturer Approval		Dispensers 1,2-3.4
Submerged Turbine Pump	Red Jacket AGP75S1-R2	Manufacturer Approval		
Dispensing Nozzles	Husky XS E-85	Manufacturer Approval		
Hose Swivels	OPW 241TPS-0492	Manufacturer Approval		
Break A-Ways	OPW 66V-0492	Manufacturer Approval		
Whip Hoses	VST V34FF-009-MRMR	Manufacturer Approval		
Pump Hoses	Goodyear Flexsteel Futura Ethan-AIII	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Michael OConnell
Job Title Vice President
Company Pemco Service Co, Inc.
Phone Number (309) 828-6134
Email pemco2@frontier.com
Contractor License # IL1224

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.