



### Blended Fuel Compatibility Form

Facility - 7020857

**Facility Name** Russell Oil Company  
**Address** 1100 North Highway 45  
 Eldorado, IL 62930  
**County** Saline  
**Contact Name** Terry Stevens  
**Phone Number** (618) 926-9180

Tank - 11

**Tank Material** Composite Single Wall  
**Tank Capacity** 2,000  
**Tank Product** E-15  
**Tank Install Date** 6/13/2001

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Single Wall	ACT 100	Manufacturer Approval	MSS ACT100 E10-E100.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping	Ameron/NOV	Lab Certification	NOV HIGH BLEND.pdf	
Shear Valve	EBW 662	Lab Certification	EBW 662 SHEAR VALVE.pdf	
Flex Hose	Hose Master FSMM 1.5	Lab Certification	HOSE MASTER FSMM.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Environ - No sump required single wall pipe	Not Applicable		Single wall pipe, no sump required

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
No interstitial Sensor - Single Wall Tank	NA	Not Applicable		NO interstice, single wall tank
ATG Probe	846396-107	Manufacturer Approval	VR Probe-109.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Red Jacket FX1V	Manufacturer Approval	RJ Mechanical LL.pdf	
Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	NA	Not Applicable		No sensors, single wall pipe

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1 series	Manufacturer Approval	OPW 2100.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	61SOM	Manufacturer Approval	OPW 61SOM.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sub Pump	FE Petro STPAGR75	Manufacturer Approval	FE Petro STP75AG.pdf	
Dispenser	Wayne E3	Lab Certification	Wayne Ovation E3.pdf	
Hoses	Contitech Futura E25	Lab Certification	Contitech E25.pdf	
Breakaway	OPW 66V	Manufacturer Approval	OPW 66V-0492.pdf	
Swivel	OPW 241 TPS	Manufacturer Approval	OPW 241TPS-0492.pdf	
Nozzle	OPW 21GE	Manufacturer Approval	OPW 21GE.pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Adam Laws

**Job Title** Sales Rep

**Company** Mid-South Steel Products, Inc.

**Phone Number** (573) 275-3002

**Email** adam@midsouthsteel.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.