

**Blended Fuel Compatibility Form**

Facility - 2021118

Facility Name Euclid Shell
Address 1200 N. River Rd.
Mount Prospect, IL 60056
County Cook
Contact Name Hahz Yaquob
Phone Number (847) 699-6420

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 7/25/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW, Pisces series dispenser & pump sump	Manufacturer Approval		
Single Wall Dispenser Sump	OPW, Pisces series	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval		
Dispenser	Gilbarco 700S	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ed Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.