

**Blended Fuel Compatibility Form**

Facility - 4040063

Facility Name Meijer Gas Station #207
Address 1800 East College Avenue
Normal, IL 71861
County McLean
Contact Name Jeff West
Phone Number (309) 888-0829

Tank - 4

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 3,000
Tank Product E-85
Tank Install Date 11/22/2000

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron	Manufacturer Approval		
Flex Connector Steel	Hose Master / FSSME - Stainless Steel	Manufacturer Approval		
Shear Valve	OPW / 10 Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes / STP Sump	Manufacturer Approval		
Under Dispenser Containment	Bravo / B7000	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root / 846391-409 Map Probe	Manufacturer Approval		
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 794380 Dual Float Hydrostatic Interstitial sensor	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root / PLLD	Manufacturer Approval		Compatibility Page 5
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root - Position Sensitive Sensor 794380-323	Manufacturer Approval		
Under dispenser containment leak detection	Veeder Root - Position Sensitive Sensor 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Emco / A1004	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling STP	Manufacturer Approval		
Nozzle	Husky XS E85 Nozzle	Manufacturer Approval		
Dispenser Hose	Futura Ethan-All E85 hose	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Brian Niederschmidt

Job Title Estimator

Company Neumayer

Phone Number (636) 515-4517

Email brian_niederschmidt@neumayerequipment.com

Contractor License # IL1502

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.