



### Blended Fuel Compatibility Form

<b>Facility - New</b>		<b>Tank - 5</b>	
<b>Facility Name</b>	QT #7191	<b>Tank Material</b>	Tank - Fiberglass Double Wall Containment Solutions
<b>Address</b>	1320 N Third Street Effingham, IL 32401	<b>Tank Capacity</b>	18,000
<b>County</b>	Effingham	<b>Tank Product</b>	B-99
<b>Contact Name</b>	Cody Thiems	<b>Tank Install Date</b>	Not Installed
<b>Phone Number</b>	(918) 615-7304		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pd f	From Permit Application

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Universal Petro Pipe	Manufacturer Approval	FFS-0164 (UL) UPP Semi-Ri gid Pipework System Datas heet.pdf	From Permit Application
Flex Connector Steel	Omega	Manufacturer Approval	Omega Flex Connectors.pdf	From Permit Application
Other Pump	Submersible	Manufacturer Approval	FE Petro STPAG.pdf	From Permit Application

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	containment solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pd f	From Permit Application
Single Wall Transition Sump	Containment Solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pd f	From Permit Application

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VEEDER ROOT 846391	Manufacturer Approval	Veeder Root 846391-407 Probe.pdf	
interstitial sensor	veeder root 791380	Manufacturer Approval	794380-345 Interstitial S ensor Solid-State Alternative Ethanol Fluid Inters tial Sensor_for_Double-Wall_Fiberglass_Tanks.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380	Manufacturer Approval	794380-351 Solid-State - Non-Discriminating_Contai nment_Sump_Sensor.pdf	From Permit Application
Electronic Pressurized Line Leak Detection	veeder root 859080	Manufacturer Approval	DPLLD 859080 _Electronic_Pressurized_Line_Leak_Det ection_Datasheet.pdf	From Permit Application

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Manufacturer Approval	OPW 1-3100 Spill Bucket Bio Compatible.pdf	From Permit Application

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW Tank Equipment Compatibility.pdf	From Permit Application

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
dispenser pumps	Gilbarco Encore	Manufacturer Approval	Gilbarco Encore Dispensers Bio Compatible.pdf	

#### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispenser Gasket and O-rings	Gilbarco Encore	Manufacturer Approval	Gilbarco Encore Dispensers Bio Compatible.pdf	

#### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasola Sealant	Gasola	Manufacturer Approval	Gasola Compatibility.pdf	

#### Correspondence Contact

<b>Submitter Name</b>	Heather Hinds	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	Construction	
<b>Company</b>	Neumayer Equipment Company	
<b>Phone Number</b>	(314) 772-4618	
<b>Email</b>	HEATHER_HINDS@NEUMAYEREQUIPMENT.COM	
<b>Contractor License #</b>	IL1502	