



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 1034844

Facility Name Fas Mart #5109
Address 2406 Bell School Rd.
Cherry Valley, IL 61016
County Winnebago
Contact Name Corinna DePropriis
Phone Number (815) 315-4973

Tank - 4

Tank Material Composite Double Wall
Tank Capacity 5,000
Tank Product E-85
Tank Install Date 11/15/2010

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Modern Welding Compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	
Single Wall UDC Sumps	OPW DSW-1543	Manufacturer Approval	OPW Compatibility Matrix. pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	794380-430	Manufacturer Approval	Veeder Root Compatibility Letter.pdf	
ATG Probe	846397-4xx	Manufacturer Approval	Veeder Root Probe & Float .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin Fueling 403169901	Manufacturer Approval	FFS-0391 MLD+ Mechanical Leak Detectors Datasheet. pdf	From Permit Application
Position Sensitive Sump Sensor	VR 794380-323	Manufacturer Approval	Veeder Root Compatibility Letter.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1c-2100	Manufacturer Approval	opw-1-2100-series-2018 (4).pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71som-412c	Manufacturer Approval	OPW Overfill Prevention Valve.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne	Wayne Ovation	Manufacturer Approval	Wayne Dispenser Meter.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Nick LeCrone
Job Title Project Manager
Company Stenstrom Petroleum
Phone Number (815) 398-6250
Email nickl@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.