



Blended Fuel Compatibility Form

Facility - 2003114

Facility Name AF Truck Center
Address 300 W. North Avenue
 Northlake, IL 60164
County Cook
Contact Name Hristo Hristov
Phone Number (773) 627-1574

Tank - 7

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 7/30/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval		
Shear Valves	OPW 10P	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	CSI	Manufacturer Approval		
Single Wall UDC's	Nupi	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root Alternative Fuels	Manufacturer Approval		
ATG Probe	Veeder Root Alternative Fuels	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Bucket - 5 gallon	OPW 2100 Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		
Overfill Alarm	Veeder Root	Manufacturer Approval		Note: Overfill Alarm is not in contact with E85

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	FE Petro AG Series Submersible Pump	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Tim Berg
Job Title President
Company Performance Tank Inc
Phone Number (847) 612-6551
Email tberg@perftank.com
Contractor License # IL881

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.