



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2019883

Facility Name St. Joseph Oil Group, Inc.

Address 6034 S. Archer Rd.
Summit, IL 60501

County Cook

Contact Name Maneev Abraham

Phone Number (708) 594-7696

Tank - 7

Tank Material N/A

Tank Capacity 6,000

Tank Product E-85

Tank Install Date Unknown

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Double Wall XERXES	XERXES Fiberglass	Lab Certification	Archer E85.pdf	From Permit Application
Xerxes DW Tank Dry interstitial	Xerxes DW Tank Dry interstitial 6000 gallon	Manufacturer Approval	Archer E85.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX	Ameron Fiberglass Dualoy 3000/LCX	Lab Certification	Archer E85.pdf	From Permit Application
Piping - Flex Connector Steel	FE Petro	Lab Certification	Archer E85.pdf	From Permit Application
Piping - Other Steel Riser	Steel	Not Applicable		From Permit Application
Piping - Other Submersible Pump	Submersible FE Petro STPAG75-VL2R	Lab Certification	Archer E85.pdf	From Permit Application
Piping - Ball Valves	FE Petro	Lab Certification	Archer E85.pdf	From Permit Application
Piping - Shear Valves	OPW 10 P	Lab Certification	Archer E85.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	Bravo	Lab Certification	Archer E85.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Lab Certification	Archer E85.pdf	From Permit Application
ATG Probe	Veeder Root 846391-410	Lab Certification	Archer E85.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
--------------------	--------------------	----------------------	---------------	---------

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressure and Leak Detection	Veeder Root 848480-001	Lab Certification	Archer E85.pdf	From Permit Application
Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Lab Certification	Archer E85.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Lab Certification	Archer E85.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Drop Tube Valve	OPW 71SOM-412C	Lab Certification	Archer E85.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne	Helex	Lab Certification	Archer E85.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Stephen Kryl
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.