



Blended Fuel Compatibility Form

Facility - 5046410

Facility Name Casey's General Store #3612
Address 524 Main Street
 Stonington, IL 62567
County Christian
Contact Name Jill Reams-Widder
Phone Number (515) 965-6238

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 7/20/2017

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/L	Manufacturer Approval		N/A
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump, LMM 3617 dispenser sump	Franklin Fueling APT	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root TLS 450 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root TLS 450 846391-4XX	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root TLS 450 DPLLD	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root TLS 450, 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 Defender	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling EBW Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump, dispensers, ball valve, hoses, nozzles, shear valves	FE Petro, Gilbarco, Morrison, Flexsteel, OPW, EBW	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Tom Oltman
Job Title General Manager
Company Total Petroleum
Phone Number (309) 251-9732
Email tom.oltman@totalpetroleum.net
Contractor License # IL1079

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.