

August 7, 2019

Jim Veverka

Crowne Industries, LTD
651 S. Sutton Road, #214
Streamwood, IL 60107
847-849-0490

Subject: Franklin Fueling Systems APT Poly Dispenser Sumps Use With E-85

Dear Jim,

Franklin Fueling Systems certifies that our APT Poly Dispenser Sumps are certified to be compatible with Fuel Ethanol, also known commercially as E85, containing 51 % to 83 % ethanol by volume under UL-2447, file MH62435. Our poly and fiberglass containment range are certified to meet the ASTM D5798 standard which has a provision for compatibility with high blend ethanol within the UL 2447 listing.

Per ASTM D5798 within the scope section 1.3 This specification formerly covered Fuel Ethanol (Ed70-Ed85) for Automotive Spark-Ignition Engines, also known commercially as E85. The nomenclature "fuel ethanol" has been changed to "ethanol fuel blends" to distinguish this product from denatured fuel ethanol Specification D4806. To facilitate blending of ethanol fuel blends that meet seasonal vapor pressure requirements, a new lower minimum ethanol content has been established.

For more information on ASTM D5798 follow the link below:

<https://www.astm.org/Standards/D5798.htm>

Sincerely,

Eric Willkomm
Supervisor, Technical Services
Franklin Fueling Systems