



Blended Fuel Compatibility Form

Facility - 2045950

Facility Name	Pilot Travel Center 1030
Address	12686 South Kedzie Ave Alsip, IL 60803
County	Cook
Contact Name	Rodney Leandro
Phone Number	(865) 588-7488

Tank - 5

Tank Material	Fiberglass Double Wall
Tank Capacity	20,000
Tank Product	B-99
Tank Install Date	7/20/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	NEF Tank Top Sump	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-345	Manufacturer Approval		
ATG Probe	Veeder Root / 846390 -109 Mag Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root / 0794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Walled Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW / 71SO-410CB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name	Brian Niederschmidt	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title	Estimator	
Company	Neumayer	
Phone Number	(636) 515-4517	
Email	brian_niederschmidt@neumayerequipment.com	
Contractor License #	IL1502	