



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 6046884

Facility Name Love's Travel Stop #758
Address 2005 Mousette Lane
Sauget, IL 62206
County St. Clair
Contact Name Kyle Collins
Phone Number (405) 834-0311

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 8/28/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	MH9061 LABEL-Shawcor 3x7. pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Transition Sump Northeast	bravo	Manufacturer Approval	bravo_afton+(1).pdf	
Single Wall STP/Tanktop Sump/UDC	Bravo	Manufacturer Approval	bravo_afton (1).pdf	
Single Wall Transition Sump Southwest	bravo	Manufacturer Approval	bravo_afton+(1).pdf	
Single Wall UDC Sump	bravo	Manufacturer Approval	bravo_afton+(1).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Franklin Fuelling	Manufacturer Approval	Loves-LL3-LL2-ULS-DIS-B99 +10-10-19.pdf	TSP LL2 125 is the probe
Float	Franklin Fueling	Manufacturer Approval	Loves-LL3-LL2-ULS-DIS-B99 +10-10-19.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling	Manufacturer Approval	Loves-LL3-LL2-ULS-DIS-B99 +10-10-19.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling	Manufacturer Approval	Loves-834-LS500-B99+4-2-2 1.pdf	
Sump Sensor with positive shutdown in Single Wall Transition Sump Northeast	VEEDER ROOT	Manufacturer Approval	Veeder-Root 794380-333.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	VEEDER ROOT	Manufacturer Approval	Veeder-Root 794380-333.pdf	
Sump Sensor with positive shutdown in Single Wall Transition Sump Southwest	VEEDER ROOT	Manufacturer Approval	Veeder-Root 794380-333.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Containment	Franklin Fueling	Manufacturer Approval	Loves-768-Defender+Spill-B99+4-21-20 (2).pdf	
Single Wall Spill Bucket	OPW	Manufacturer Approval	OPW+1-2105+compatibility+ sheet (2).pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	incon	Manufacturer Approval	TS-RA1, TS-RA2, and TS-RK Tank Overfill Alarms Installation Guide.pdf _ Franklin Grid Support.pdf	Replacing from Permit Application.
Overfill Drop Tube Valve	FRANKLIN	Manufacturer Approval	Drop Tubes _ Franklin Electric Fueling Systems.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Franklin Fueling	Manufacturer Approval	BIO-STP-LOVES (5).pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Franklin Fueling	Manufacturer Approval	BIO-STP-LOVES+(5) (2).pdf	Gaskets and Seals in Pump

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope and Adhesive	Federal Process	Manufacturer Approval	E+seal+pipe+dope+compatibility (3).pdf	

Correspondence Contact

Submitter Name SAMANTHA HUNTER ☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title customer service coordinator
Company Neumayer Equipment Company, Inc.
Phone Number (314) 772-4501
Email testing@neumayerequipment.com
Contractor License # IL1502