



### Blended Fuel Compatibility Form

Facility - 2009090

<b>Facility Name</b>	Marathon
<b>Address</b>	2800 West 63rd Street Chicago, IL 60629
<b>County</b>	Cook
<b>Contact Name</b>	Khader Amad
<b>Phone Number</b>	(708) 372-6732

Tank - 6

<b>Tank Material</b>	Fiberglass Single Wall
<b>Tank Capacity</b>	10,000
<b>Tank Install Date</b>	7/1/1989
<b>Current Product on File</b>	Gasoline - Regular
<b>Newly Reported Product</b>	E-85

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Xerxes	Manufacturer Approval	xerxes tanks.pdf	
Tank interior lining	Bridgeport lining material	Manufacturer Approval	bridgeport tank lining.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron 3000/L	Manufacturer Approval	ameron fiberglass pipe.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling, TSM-4245	Manufacturer Approval	FFS-0691 UL 2447 Product Description Datasheet.pdf	
Single Wall Dispenser Sump	Franklin Fueling, LMM-series	Manufacturer Approval	FFS-0691 UL 2447 Product Description Datasheet.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank monitoring system	Veeder Root TLS 350	Manufacturer Approval	veeder root sensors all.pdf	
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval	veeder root probes.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root, 794380-323	Manufacturer Approval	veeder root sensors all.pdf	
Mechanical Pressurized Line Leak Detection	Franklin Fueling Systems STP-MLD+AG	Manufacturer Approval	franklin mlld.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling, Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Correspondence Contact

<b>Submitter Name</b>	Ed Angell	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	Project Manager	
<b>Company</b>	B&K Equipment Company	
<b>Phone Number</b>	(708) 474-3344	
<b>Email</b>	ed@bkequip.com	
<b>Contractor License #</b>	IL1207	