

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Lenny's Gas N Wash 65th & Central, LLC
Address 5611 W 65th Street
Bedford Park, IL 60638
County Cook
Contact Name Leonard McEnery
Phone Number (708) 444-0117

Tank - 3

Tank Material Tank - Fiberglass Double Wall
XERXES
Tank Capacity 10,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	E85 all.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass Dualoy 3000/LCX	Manufacturer Approval	e85 frp pipe.pdf	New from Permit Application.
Ball Valves	Franklin Fueling SS Ball Valve	Manufacturer Approval	e85 franklin all.pdf	New from Permit Application.
Other Pump	Submersible	Manufacturer Approval	e85 franklin stp.pdf	New from Permit Application.
Other Riser	Steel	Lab Certification	E85 equipment approvals U S Department of Energy.pdf	New from Permit Application.
Flex Connector Steel	Hosemaster	Manufacturer Approval	e85 -hosemaster.pdf	New from Permit Application.
Shear Valves	OPW 10 Series	Manufacturer Approval	e85 opw.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump UDC BravoB1250-S30	Bravo	Manufacturer Approval	e85 bravo.pdf	New from Permit Application.

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root	794380-345	Lab Certification	E85 sensors.pdf	New from Permit Application.
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	e85 probe.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	e85 plld.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 794380-323	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Manufacturer Approval	e85 franklin all.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	e85 drop tube.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	franklin	Manufacturer Approval	e85 franklin stp.pdf	
Dispenser	gilbarco E700	Manufacturer Approval	e85 gilbarco.pdf	
Nozzle	opw 21gu-0992-e85	Manufacturer Approval	e85 opw.pdf	
Hose	Continental Hose 53233712412169	Manufacturer Approval	e85 contental hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None that are not part of an approved device	None that are not part of an approved device.	Not Applicable		None being used that are no part of an approved device

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasola E Seal	Gasola E Seal	Manufacturer Approval	e85 dope.pdf	

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.