

**Blended Fuel Compatibility Form**

Facility - 2020298

Facility Name Citgo
Address 17011 South Park Avenue
South Holland, IL 60473
County Cook
Contact Name Vishal Patel
Phone Number (773) 858-7689

Tank - 13

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Install Date 4/1/2010
Current Product on File Diesel Fuel
Newly Reported Product E85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval		
Shear Valve	OPW-10 Plus Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling -Tank Sump	Manufacturer Approval		
Single Wall UDC Sump	Petroleum Containment Inc-UDC	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-345	Manufacturer Approval		
ATG Probe	Veeder Root-846397-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin Fueling-STP-MLD+AG	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root-794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW- 2100 Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling-STP-AG Series	Manufacturer Approval		
Dispenser	Gilbarco- Encore Dispenser	Manufacturer Approval		
Nozzle	OPW-11BP-E85	Manufacturer Approval		
Hose	Continental-Conti Tech-E85 Hose	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.