



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2045736

Facility Name Speedway #2120
Address 1830 Route 30 & Wolf
Crossing Rd.
Oswego, IL 60543
County Kendall
Contact Name Adriana Gonzalez
Phone Number (630) 554-3468

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 12/4/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks	Manufacturer Approval		
Shear Valve	OPW-10P-0152	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval		
Single Wall UDC Sump	Petroleum Containment Inc	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-345	Manufacturer Approval		
ATG Probe	Veeder Root-846391-507	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root-859080-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root-794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-2100c Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM Series	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Encore Series Flex Dispenser	Gilbarco Veeder Root	Manufacturer Approval		
Submersible Turbine Pump	Franklin Fueling- PMA Series	Manufacturer Approval		
Nozzle	OPW-11BP-0992	Manufacturer Approval		
Hose	Good year/6 Inch Black Hardwall Hose Male	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company Ampsco services
Phone Number (708) 795-9052
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.