



Blended Fuel Compatibility Form

Facility - 2034132

| | |
|----------------------|--|
| Facility Name | KNK Gas and Wash d/b/a Marathon |
| Address | 2151 W. Army Trail Road Addison, IL 60101 |
| County | Du Page |
| Contact Name | Rizwan Khan |
| Phone Number | (630) 802-0000 |

Tank - 3

| | |
|--------------------------------|-----------------------|
| Tank Material | Composite Double Wall |
| Tank Capacity | 6,000 |
| Tank Install Date | 10/13/1995 |
| Current Product on File | Gasoline - Premium |
| Newly Reported Product | E85 |

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|-----------------------|--------------------|-----------------------|---|---------|
| Composite Double Wall | Glasteel II | Manufacturer Approval | Glasteel II BioFuels Compatibility 2018.pdf | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|--------------------|-----------------------|----------------------------|---------|
| Fiberglass Double Wall | NOV AMERON | Manufacturer Approval | ameron fiberglass pipe.pdf | |
| Shear Valve | OPW 10BFP-5726 | Manufacturer Approval | OPW compatibility.pdf | |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------------|--------------------|-----------------------|---|---------|
| Single Wall STP/Tanktop Sump | Total Containment | Manufacturer Approval | flexpip4 EPA OUST Letter Piping Suppliers.pdf | |
| Single Wall UDC Sump | Total Containment | Manufacturer Approval | flexpip4 EPA OUST Letter Piping Suppliers.pdf | |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|------------------------|-----------------------|--|---------|
| Non-Discriminating Interstitial Monitoring Sensors | Veeder Root 794380-430 | Manufacturer Approval | Veeder-Root tank interstitial sensor.pdf | |
| ATG Probe | Veeder Root 846397-407 | Manufacturer Approval | veeder root probes.pdf | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|------------------------|-----------------------|-----------------------------|---------|
| Mechanical Pressurized Line Leak Detection | Franklin 403169901 | Manufacturer Approval | Franklin MLD AG.pdf | |
| Sump Sensor in Single Wall STP/Tanktop Sump | Veeder Root 794380-323 | Manufacturer Approval | veeder root sensors all.pdf | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|--------------------------|---------|
| Single Wall Spill Bucket | OPW 101BG | Manufacturer Approval | Opw spill containers.pdf | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|---------------------|-----------------------|------------------------------|---------|
| Overfill Drop Tube Valve | Emco A1100EVR-058EM | Manufacturer Approval | EMCO Modular Drop Tubes.p df | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|----------------------------|-----------------------|---|---------|
| Submersible Turbine Pump | Franklin Stpag75-vl2-00 | Manufacturer Approval | franklin stp.pdf | |
| Dispenser | Wayne Anthem UX, EB23/5/M2 | Manufacturer Approval | Wayne Ovation EB23.pdf | |
| Nozzle | Opw 11bp | Manufacturer Approval | opw-11bp-series-ethanol-nozzles_2018.pdf | |
| Hose | Continental | Manufacturer Approval | Continental_Goodyear_flex steel hoses.pdf | |

Gaskets & Seals Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|--|---------|
| Fill Cap | OPW | Manufacturer Approval | opw-634-series-tight-fill - top-seal-caps-2018.pdf | |

Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|-----------------|---------|
| Thread Sealant | Gasoil E-seal | Manufacturer Approval | gasoil dope.pdf | |

Correspondence Contact

Submitter Name Darren White
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email dj.white@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.