



### Blended Fuel Compatibility Form

Facility - 6042984

<b>Facility Name</b>	Flying J Travel Plaza #642
<b>Address</b>	140 Racehorse Drive Alorton, IL 62207
<b>County</b>	St. Clair
<b>Contact Name</b>	Gregory Jantz
<b>Phone Number</b>	(865) 588-7488

<b>Tank - 4</b>	
<b>Tank Material</b>	Fiberglass Brine Filled Double Wall
<b>Tank Capacity</b>	20,000
<b>Tank Install Date</b>	1/19/2006
<b>Current Product on File</b>	Gasoline - Regular
<b>Newly Reported Product</b>	E15

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval		

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Western FG/co flex	Manufacturer Approval		
Shear Valve	EBW shear valve	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Western FB	Manufacturer Approval		
Single Wall UDC Sump	Western FB	Manufacturer Approval		

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/846390-117	Manufacturer Approval		
interstitial sensor	Veeder Root/794390-409	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin/FE-STP-MLD+AG	Manufacturer Approval		
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root/ 794380-208	Manufacturer Approval		

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW/1-series	Manufacturer Approval		

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW/OPW-71SO-410C	Manufacturer Approval		

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin/FE-STPAGM200-VL2-19	Manufacturer Approval		
Dispenser	Gilbarco/NL1	Manufacturer Approval		
Nozzle	Catlow	Manufacturer Approval		
Hose	Futura/continental	Manufacturer Approval		

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

<b>Submitter Name</b>	Sarah Faue	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	Environmental Specialist	
<b>Company</b>	Pilot Travel Centers	
<b>Phone Number</b>	(865) 588-7488	
<b>Email</b>	Sarah.fae@Pilottravelcenters.com	