

**Blended Fuel Compatibility Form**

Facility - 2021387

Facility Name Flip Petromart
Address 1125 Aurora Avenue
Route 25 and Indian Trail
Aurora, IL 60505
County Kane
Contact Name Amaan Fazal
Phone Number (630) 835-9107

Tank - 10

Tank Material N/A
Tank Capacity 5,000
Tank Product E85
Tank Install Date Unknown

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	UGPetroleumStorageTankWar r.5.1.2019.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	Ethanol Testing.pdf	New from Permit Application.
Shear Valve	10 BF 5725	Manufacturer Approval	20230626123015644.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW TSM4536	Manufacturer Approval	20230626123015644.pdf	New from Permit Application.
UDC sump	OPW polyethylene	Manufacturer Approval	20230626123015644.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Solid State veeder root 0794380-345	Manufacturer Approval	20230626131604315.pdf	New from Permit Application.
ATG Probe	Mag plus stainless Veeder Root	Manufacturer Approval	vr-probe.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Vaporless Manufacturing LD2-SSVS	Manufacturer Approval	20230525154110288 (1).pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 0794380-321	Manufacturer Approval	20230525163930680 (2).pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100	Manufacturer Approval	opw-edge-dwsc-catalog (1).pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61T-SS	Manufacturer Approval	20230626123015644.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sealants	Gasola E seal GE 16	Manufacturer Approval	SealantReferenceGuide.pdf	
Submersible Turbine Pump	Red Jacket ACP -75-SI UL79A E85	Manufacturer Approval	20230622101606673.pdf	
Dispenser	Wayne Ovation B/23 4 3+1 E 85	Manufacturer Approval	Wayne Ovation fuel dispenser brochure.pdf	
Nozzle	11 BP MBF 0992 E 85	Lab Certification	SQ_8121199 (1).pdf	
Hose	Flexsteel Futura 08D 12x912 BM 16 BF	Manufacturer Approval	20230622102434671 (3).pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Jan Kopytek
Job Title President
Company CAT Builders USA, Inc.
Phone Number (630) 670-6280
Email Jankopytek@gmail.com
Contractor License # IL002381

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.