

**Blended Fuel Compatibility Form**

Facility - 3028203

Facility Name Pilot Travel Center #476
Address 900 Plaza Avenue
Woodhull, IL 61490
County Henry
Contact Name Scott Epping
Phone Number (309) 334-2191

Tank - 13

Tank Material Fiberglass Double Wall
Tank Capacity 16,000
Tank Product E15
Tank Install Date 11/23/2010

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW/E401	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	ameron dualoy 3000 lcx data sheet.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	NEF-SWSTSCMPMB32	Manufacturer Approval	NEF.pdf	
Single Wall UDC Sump	OPW/flexworks	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846390-109	Manufacturer Approval	577014-449-08.pdf VR veeder root ATG probe E15 compatibility.pdf	
Non-Discriminating Interstitial Monitoring Sensors	VR-0794390-409	Manufacturer Approval	577013-750-12_AE Veeder root interstitial monitor proof.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro FE-STP-MLD+AG	Manufacturer Approval	_assets_products_documents_FE-Petro-mechanical-leak-detectors.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 208	Manufacturer Approval	577013-750-08_Piping_Sump_Sensor.pdf veeder root sump sensor 208.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-Series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Only Removed Ball Float Vent Valve	N/A	Not Applicable		We do not use ball floats
Overfill Drop Tube Valve	OPW -71SO-410C	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Red Jacket P200UI-3RJ2	Manufacturer Approval	576047-305 red jacket mot or e15 proof.pdf	
Dispenser	Gilbarco Veeder Root NL1	Manufacturer Approval	01EncoreDispensers Booklet.pdf E15 compatible.pdf	
Nozzle	OPW-11BP-8400-E25-UL	Manufacturer Approval	Equipment-Compatibility.pdf for E15 OPW dispenser sumps.pdf	
Hose	CT-3409-E85	Manufacturer Approval	IFS-En-Petroleum-Dispensing-Hose-Brochure.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
GASKETS	GORMAN RUPP	Manufacturer Approval	b99+Gorman+Rupp PUMP.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
DOPES	GORMAN RUPP	Manufacturer Approval	b99+Gorman+Rupp PUMP.pdf	

Correspondence Contact**Submitter Name** SAMANTHA HUNTER**Job Title** CUSTOMER SERVICE
COORDINATOR**Company** NEUMAYER EQUIPMENT**Phone Number** (314) 772-4501**Email** testing@neumayerequipment.com**Contractor License #** IL1502☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.