

**Blended Fuel Compatibility Form**

Facility - 2046611

Facility Name Casey's General Store #3725
Address 480 E. Veterans Parkway
Yorkville, IL 60560
County Kendall
Contact Name Cynthia Baumann
Phone Number (630) 533-8987

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 5/3/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump, LMM 3617 dispenser sump	Franklin Fueling APT	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root TLS 450 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root TLS 450 846391-4XX	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root TLS 450 DPLLD	Manufacturer Approval		
Siphon Bar	Veeder Root TLS 450, 794380-208	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root TLS 450, 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 Defender	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling EBW Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump, dispensers, ball valve, hoses, nozzles, shear valves	FE Petro, Gilbarco, Morrison, Flexsteel, OPW, EBW	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Tom Oltman

Job Title General Manager

Company Total Petroleum Service Co

Phone Number (130) 925-1973

Email Tom.Oltman@TotalPetroleum.net

Contractor License # IL1079

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.