

**Blended Fuel Compatibility Form**

Facility - 4001363		Tank - 5	
Facility Name	South Central FS, Inc. - Sullivan C Store	Tank Material	Fiberglass Single Wall
Address	305 S. Hamilton Street Sullivan, IL 61951	Tank Capacity	10,000
County	Moultrie	Tank Product	E-85
Contact Name	Stanley Joergens	Tank Install Date	10/22/1989
Phone Number	(217) 342-9231		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Owens Corning 10,000 GAL FRP	Not Applicable		This tank was internally lined in 2010
Tank Lining	Armor Shield TM 300M Lining	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping	NOV Red Thread RT IIA	Lab Certification		
Flex Connector Steel	Fire Flex FFUL20X15HMXHM	Lab Certification		
Shear Valve	EBW 662 662502902 AGB model	Manufacturer Approval		On Order

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT TSM 4542	Manufacturer Approval		Does not normally contain E-85 fuel
Dispenser Sumps 1&2, 3&4	APT LMM 3617	Manufacturer Approval		Does not normally contain E-85 fuel

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root PLLD	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	EBW 308	Not Applicable		Removing and installing Franklin Fueling Defender AGB compatible OPV drop tube
Over Fill Drop Tube	Franklin Fueling Defender OPV 708691921 AGB	Manufacturer Approval		On Order

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Red Jacket AGP75S1	Manufacturer Approval		
Fuel Dispensers 1&2, 3&4	Gilbarco Encore 500S Flex Fuel	Manufacturer Approval		
Pump Hoses	Franklin Fueling FLXE200900 hose, FLXE200009 whip	Lab Certification		
Dispensing nozzles	OPW 21GE	Lab Certification		
Break a ways	OPW 66v-0492	Lab Certification		
Hose Swivels	OPW 241TPS-0492	Lab Certification		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Mike OConnell
Job Title Vice President
Company Pemco Service Co, Inc.
Phone Number (309) 828-6134
Email pemco2@frontier.com
Contractor License # IL1224

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.