



Blended Fuel Compatibility Form

Facility - 4044048

| | |
|----------------------|---|
| Facility Name | Pilot Travel Center #468 |
| Address | 815 Highway Route 24W Gilman, IL 60938 |
| County | Iroquois |
| Contact Name | Joey Cupp |
| Phone Number | (865) 588-7488 |

Tank - 6

| | |
|--------------------------|------------------------|
| Tank Material | Fiberglass Double Wall |
| Tank Capacity | 20,000 |
| Tank Product | B-99 |
| Tank Install Date | 12/1/2011 |

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|--------------------|-----------------------|---------------|---------|
| Fiberglass Double Wall | XERXES | Manufacturer Approval | | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|------------------------|-----------------------|---------------|---------|
| Fiberglass Double Wall | Ameron Dualoy 3000/LCX | Manufacturer Approval | | |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------------|------------------------|-----------------------|---------------|---------|
| Single Wall STP/Tanktop Sump | Xerxes / Tank Top Sump | Manufacturer Approval | | |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|-------------------------------------|-----------------------|---------------|---------|
| Non-Discriminating Interstitial Monitoring Sensors | Veeder Root / 0794380-345 | Manufacturer Approval | | |
| ATG Probe | Veeder Root / 846390 Mag Plus Probe | Manufacturer Approval | | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|---------------------------|-----------------------|---------------|---------|
| Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Veeder Root / 0794380-321 | Manufacturer Approval | | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|---------------------|-----------------------|---------------|---------|
| Single Wall Spill Bucket | OPW / 1-2100 Series | Manufacturer Approval | | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|---------------|---------|
| Overfill Drop Tube Valve | OPW / 71SO-410CB | Manufacturer Approval | | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|---------------|---------|
| Suction Pump | Gorman Rupp | Manufacturer Approval | | |

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

| | | |
|-----------------------------|---|---|
| Submitter Name | Brian Niederschmidt | <input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules. |
| Job Title | Estimator | |
| Company | Neumayer Equipment Company | |
| Phone Number | (636) 515-4517 | |
| Email | brian_niederschmidt@neumayerequipment.com | |
| Contractor License # | IL1502 | |