



September 28, 2018

Ms. Roberta Brusi
NUPI INDUSTRIE ITALIANE SpA
Via Stefano Ferrario
Z I Sud Ovest
Busto Arsizio, Va, 21052, IT

Our Reference: File MH25887, Vol 1

Project 4788390844

:

Dear Ms. Roberta Brusi:

This is in regards to our testing of underground pipe systems in accordance with UL 971 Standard for Nonmetallic Underground Piping for Flammable Liquids- Edition 1 - Revision Date 2006/03/02. UL evaluates the pipe and fittings as a system. So both the pipe and fittings are subjected to long term exposures at elevated temperature in 100% ASTM Reference Fuel C, 70% ASTM Reference Fuel C/30% Ethanol, 50% ASTM Reference Fuel C/50% Ethanol and 100% Ethanol. This range of exposures is intended to evaluate the pipe system for any blend of ethanol from zero to 100%.

Please let me know if you have any questions.

Best regards,

Very truly yours,

Wayne Doversberger
Senior Staff Engineer
Wayne.B.Doversberger@ul.com