



### Blended Fuel Compatibility Form

Facility - 7025619

<b>Facility Name</b>	Speedway #7423
<b>Address</b>	201 North Avenue Ina, IL 62846
<b>County</b>	Jefferson
<b>Contact Name</b>	Travis Powell
<b>Phone Number</b>	(937) 863-6513

Tank - 14

<b>Tank Material</b>	Fiberglass Double Wall
<b>Tank Capacity</b>	6,000
<b>Tank Product</b>	E-85
<b>Tank Install Date</b>	11/8/2019

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	biofuel-compatibility containment solutions.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0164 (UL) UPP Semi-Rigid Pipework System Datasheet.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC	franklin fueling	Manufacturer Approval	FFS-0691 UL 2447 Product Description Datasheet.pdf	
Single Wall STP/Tanktop Sump	containment solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	veeder root	Manufacturer Approval	846391-409 Stainless Steel Mag Plus In-Tank Probe Alternative Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors With Monitor	veeder root	Manufacturer Approval	577013-750-13_Solid-State Alternative Ethanol Fluid Interstitial Sensor for Double-Wall Fiberglass Tanks.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	DPLLD 859080_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	veeder root	Manufacturer Approval	577013-750-06_Solid-State - Non-Discriminating Dispenser Pan Sensor.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1C-2100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

**Overfill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Franklin fueling TS-RA2	Not Applicable		From Permit Application
Overfill Drop Tube Valve	OPW	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

**Pump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FRANKLIN FUELIJG	Manufacturer Approval	STPAGR150-VL2-15 1.5 Hp Fixed Speed Submersible Turbine Pumps Datasheet.pdf	

**Gaskets & Seals Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
GASKETS	OPW	Manufacturer Approval	opw-62m-monitor-probe-cap-adaptor-kit-2018.pdf	

**Joint Dopes & Adhesives Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
adhesive	adhesive	Manufacturer Approval	gasoline seal adhesive.pdf	

**Correspondence Contact****Submitter Name** Heather HINDS**Job Title** CONSTRUCTION**Company** Neumayer Equipment Company**Phone Number** (314) 210-5036**Email** HEATHER\_HINDS@NEUMAYEREQUIPMENT.COM**Contractor License #** IL1502
 By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.