



Blended Fuel Compatibility Form

Facility - 2032993

Facility Name Speedway #1419
Address 15060 S. Bell Road
 Homer Glen, IL 60491
County Will
Contact Name Shawn Monroe
Phone Number (708) 301-2388

Tank - 10

Tank Material Composite Double Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 7/24/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Glasteel II Brochure_2.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Environ	Lab Certification	E85 flex pipe.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall UDC	OPW	Manufacturer Approval	other-equipment-compatibility.pdf	
Single Wall STP/Tanktop Sump	OPW	Manufacturer Approval	other-equipment-compatibility.pdf	
Single Wall UDC Sump	OPW Flexworks	Manufacturer Approval	e85 opw.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VR-846391-407	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors	VR-794380-430	Manufacturer Approval	577013-750-16_Interstitial_High_Alcohol_Sensor_for_Steel_Tanks.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	e85 plld.pdf	Replacing - Electronic Pressurized Line Leak Detection from Permit Application.
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	VR-794380-430	Manufacturer Approval	577013-750-16_Interstitial_High_Alcohol_Sensor_for_Steel_Tanks.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-2100C	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Encore 700S	Gilbarco	Manufacturer Approval	Encore Flex Fuel Dispenser _ Gilbarco Veeder-Root.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.