



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7046156

Facility Name Hucks 379
Address 2710 Old State route 13
Marion, IL 62959
County Williamson
Contact Name Sandi Hale
Phone Number (618) 384-6285

Tank - 1

Tank Material Fiberglass Double Wall
Tank Capacity 15,000
Tank Install Date 6/21/2016
Current Product on File Gasoline - Regular
Newly Reported Product E15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Xerxes 10' diameter 15,000 gallon	Manufacturer Approval	xerxes (1).pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron AME22466486 2"x32' LCS Pipe	Manufacturer Approval	NOV Fiber Glass Systems Piping compatibility-letters-11-07-2023.pdf	Highlighted section from manufacturer
Shear Valve	OPW OPW10P0152	Manufacturer Approval	opw-10-series-emergency-shut-off-valves-2018.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
OPW	OPWFWFDS4021	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Xerxes	Xerxes 4236	Manufacturer Approval	ZCL-XERXES-Sump-Brochure-web-16.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root Model 794380-208	Manufacturer Approval	Veeder Root Model 794380-208.pdf	
ATG Probe	VEE846390109	Manufacturer Approval	577014-449-09_C.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection South	FE Petro STP-MLD 200VL2	Manufacturer Approval	FEPSTPMLD.pdf	
Mechanical Pressurized Line Leak Detection North	FE Petro STP-MLD 200VL2	Manufacturer Approval	FEPSTPMLD.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump South	Veeder Root VEE859080002	Manufacturer Approval	Veeder Root sump compatibility.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump North	Veeder Root VEE859080002	Manufacturer Approval	Veeder Root sump compatibility.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C3112P	Manufacturer Approval	_assets_products_document_s_1C-3112P_1C-3132P.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	OPW 61TP	Manufacturer Approval	opw-opw-61tp-tank-bottom- protector-2018.pdf	
Suction Pump	OPW 61TP	Manufacturer Approval	opw-opw-61tp-tank-bottom- protector-2018.pdf	
Dispenser	Gilbarco Encor 700S	Manufacturer Approval	Encore_flex_fuel.pdf	
Nozzle	Gilbarco 700	Manufacturer Approval	Encore_flex_fuel.pdf	
Hose	Husky CP12ET08	Manufacturer Approval	18-10-Wirebraid-E0-E85.pd f	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Paulette Hosick	
Job Title	Director of Petroleum	
Company	Martin & Bayley, Inc dba Hucks	
Phone Number	(618) 382-2334	
Email	phosick@hucks.com	