



Blended Fuel Compatibility Form

Facility - 1046934

Facility Name	Pilot Travel Center #1181
Address	1201 E. IL Route 38 Rochelle, IL 61068
County	Ogle
Contact Name	Michael Smith
Phone Number	(423) 710-4775

Tank - 3

Tank Material	Fiberglass Double Wall
Tank Capacity	30,000
Tank Product	B-99
Tank Install Date	10/17/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valves	OPW / 10 Series	Manufacturer Approval		5" Fire Flex
Flex Connectors	OPW / FC20 Stainless Flex Connector	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	PCI / 4800 Series	Manufacturer Approval		
Single Wall Transition Sump	PCI / Below Grade Series	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-345	Manufacturer Approval		
ATG Probe	Veeder Root / Mag Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
American Suction Piping Sump	Veeder Root / 794380-351 Sump Sensor	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / 794380-321 UDC Sensor	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW / 1-2100 Series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW / 71SO-410CB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Gilbarco / Encore S NA1	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Fittings	NOV Ameron / Fittings	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Glue	NOV Ameron / Psx-20 Piping Glue	Manufacturer Approval		

Correspondence Contact

Submitter Name Brian Niederschmidt
Job Title Estimator
Company Neumayer
Phone Number (636) 515-4517
Email brian_niederschmidt@neumayerequipment.com
Contractor License # IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.