



Blended Fuel Compatibility Form

Facility - 2020694

Facility Name	FS005 Sunnyside
Address	4820 W. Sunnyside Chicago, IL 60630
County	Cook
Contact Name	Curtis Anderson
Phone Number	

Tank - 4

Tank Material	Fiberglass Double Wall
Tank Capacity	12,000
Tank Product	E-85
Tank Install Date	11/20/1998

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	A.O. Smith	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes	Manufacturer Approval		
UDC (Under Dispenser Containment)	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	veeder root 794380-345	Manufacturer Approval		
ATG Probe	veeder root 846397-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	fe petro 403169901	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	veeder root 794380-323	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	veeder root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	opw 1-2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 61-som	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	red jacket ag stp	Manufacturer Approval		
PV vent cap	OPW 623v	Manufacturer Approval		
Fill adapter	opw 633t	Manufacturer Approval		
Shear valve	opw10	Manufacturer Approval		
Nozzle	11bp E85 nozzle	Manufacturer Approval		
Swivel	opw241tps	Manufacturer Approval		
Breakaway	opw 66v	Manufacturer Approval		
Dispenser	Wayne Reliance	Manufacturer Approval		
Hose	Continental contitech flex steel futra E85	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread Sealant	Gasola E-Seal	Manufacturer Approval		

Correspondence Contact

Submitter Name Tim Smith
Job Title PO
Company K Plus Mechanical
Phone Number (815) 216-7715
Email tsmith@kplus.com
Contractor License # IL002335

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.