



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2044997

Facility Name Lenny's Gas N Wash, LLC
Address 8810 W. 191st Street
Mokena, IL 60448
County Will
Contact Name Kim Isaacson
Phone Number (708) 479-1300

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 11/10/2011

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	e85 xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	A.O. Smith	Lab Certification	e85 frp pipe.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	xerxes	Lab Certification	e85 xerxes.pdf	
Single Wall UDC Sump	Bravo	Manufacturer Approval	e85 bravo.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794390-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Lab Certification	e85 veeder PLLD.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Lab Certification	e85 veeder sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1c-3112D	Manufacturer Approval	e85 opw all.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO-410M	Manufacturer Approval	e85 drop tube.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco	E700 S	Lab Certification	e85 gilbarco.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Steve Kryl

Project Manager

Anderson Pump Service, Inc.

(708) 243-9081

steve@andersonpump.com

IL002275

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.