



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2047182

Facility Name True North Energy, LLC
Address 2345 West Bartlett Road
Bartlett, IL 60103
County Du Page
Contact Name David Nye
Phone Number (877) 245-9336

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-15
Tank Install Date 7/12/2021

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Double Wall Containment Solutions	Containment Solutions	Manufacturer Approval	CSI Compatibility...	From Permit Application
Tank - Fiberglass Double Wall Containment Solutions	Containment Solutions	Manufacturer Approval	CSI Compatibility...	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Flexible Double Wall Franklin Fueling Systems UPP	Franklin Fueling Systems UPP	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank Sumps and Dispenser Sumps	Containment Solutions tank sumps and Franklin Fueling dispenser sumps	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	Veeder Root Compa...	From Permit Application
ATG Probe	Veeder Root	Manufacturer Approval	Veeder Root Compa...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veeder Root Compa...	From Permit Application
Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown	Veeder Root	Manufacturer Approval	Veeder Root Compa...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Double Wall Spill Bucket	OPW	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Drop Tube Valve	OPW	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible	FE Petro	Manufacturer Approval	FE Petro Compatib...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasket	OPW	Manufacturer Approval	E 15 DOCUMENTATIO...	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoil	Manufacturer Approval	Gasoil Compatibi...	

Correspondence Contact

Submitter Name Warren Cherner
Job Title President
Company Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
Phone Number (847) 465-4000
Email warren@metrotank.com
Contractor License # IL102

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.