

CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-MH1821
Report Reference MH1821-20020809
Issue Date 2019-MARCH-01

Issued to: WAYNE FUELING SYSTEMS LLC
3814 JARRETT WAY
AUSTIN TX 78728

**This certificate confirms that
representative samples of**

FLAMMABLE LIQUID DISPENSING DEVICES, POWER
OPERATED

See addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See addendum page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-MH1821
Report Reference MH1821-20020809
Issue Date 2019-MARCH-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Remote Control Models:

Power-operated flammable liquid dispensing devices, Ovation Series, Model B, R, HL or HS followed by 1 or 2, followed by 1, 2, 3 or 4, followed by 1, 2, 3, 4 or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, 1, 3, 4, 5, 6, or 7, followed by C, D, or S followed by 0, 1, 2, 3, 4, 7, 8 or D6, may be followed by one or more of the following option suffixes, 2, 6, 7, 9, E, G, H, I, J, K, L, L1, M, N, P, S, T, or U, followed by one or more of the following option suffixes A, C, D, F, F1, G, H, L, M, N, O, R, R3 U, V, W, W1, X, Y, or Z.

Power-operated flammable liquid dispensing devices, Ovation Series, Model B, R, HL followed by 1 or 2, followed by 1, 2, 3 or 4, followed by 1, 2, 3, 4 or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, followed by C, D, or S followed by 1, 2, 3, 4, 7, 8, or D6, may be followed by one or more of the following option suffixes, 2, 6, G, I, J, K, L, L1, M, N, P, S, T, or U, followed by one or more of the following option suffixes A, F, F1, G, H, L, M, N, O, R, R3 U, V, W, W1, X, or Y.

Power-operated flammable liquid dispensing devices, Ovation Series, Model E, followed by B or R, followed by 1 or 2, followed by 1, 2, 3, or 4 followed by 1, 2, 3, 4, or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, followed by D, followed by 0, 1, 2, 3, 4, 7, 8, or D6, may be followed by one or more of the following option suffixes, C, D, E, G, H, I, J, K, L, L1, M, M2 N, P, R, R3, S, T, U, W, W1, X, Y, 6 and 7.

Standard(s) for Safety: UL 1238, Control Equipment for Use With Flammable Liquid Dispensing Devices
UL 87, Power-Operated Dispensing Devices For Petroleum Products
CAN/CSA B346-M1980, Power-Operated Dispensing Devices for Flammable Liquids
C22.2 No. 22-2018, Electrical Equipment for Flammable and Combustible Fuel Dispensers
UL 121201 Nonincendive Electrical Equipment for use in Class I and II, Division 2 And Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213-2017, Nonincendive Electrical Equipment for use in Class I and II, Division 2 And Class III, Divisions 1 and 2 Hazardous (Classified) Locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

