OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 6018498

Facility Name	Pilot Travel Center #249
Address	820 Edwardsville Road Troy, IL 62294
County	Madison
Contact Name	Pat Heinkebein
Phone Number	

Tank - 15

Tank Material	Steel Double Wall
Tank Capacity	20,000
Tank Product	B-99
Tank Install Date	1/23/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Double Wall	Highland Tank Titan Jacketed	Manufacturer Approval	highland-tank.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy 3000 LCX Data Shee t.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo /	Manufacturer Approval	Bravo_Sumps_AlternativeFu els_R3.pdf	
Single Wall UDC Sump	OPW	Manufacturer Approval	OPW SINGLE WALL SUMP.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root / 846391-407 Map Probe	Manufacturer Approval	Veeder Root Letter - Mag Probe - B99 Compatiblity. pdf	
Interstitial Sensor	Veeder Root / Interstitial Sensor	Manufacturer Approval	577013-750-11_Solid-State (Optical) Discriminat-in g Interstitial Sens.pdf	
SIR and Prec Tightness Testing	Warren Rogers Associates Petro Network S3 Version D	Manufacturer Approval	Warren Rogers Associates, Inc. C.pdf	New from Permit Application.
Vacuum Gauge	36TW19	Manufacturer Approval	WINTERS, 0 in Hg to 30 in Hg, 2 1_2 in Dial, Lead-Free Vacuum Gauge - 36TW1 9_PFQ801LF - Grainger.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	GORMAN RUPP	Manufacturer Approval	PUMP.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / Piping sump sensor	Manufacturer Approval	Non Descriminating Leak S ensor 794380-321.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW / 1-2100 Series	Manufacturer Approval	FFS-0638 (EN) EBW Series Spill Containers Datashee t.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
OVERFILL DROP TUBE VALVE	opw 71so-410cb	Manufacturer Approval	DROP TUBE 71SO.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Viking Biofuel Pump	Manufacturer Approval	Viking Pump Biofuel Infor mation.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name SAMANTHA HUNTER
Job Title CUSTOMER SERVICE COORDINATOR
Company Neumayer Equipment Company, Inc.
Phone Number (314) 772-4501
Email testing@neumayerequipment.com
Contractor License # IL1502

☑ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.