



### Blended Fuel Compatibility Form

<b>Facility - 2007023</b>		<b>Tank - 6</b>	
<b>Facility Name</b>	75th & Cottage Food & Gas, Inc.	<b>Tank Material</b>	Fiberglass Double Wall
<b>Address</b>	7560 S. Cottage Grove Chicago, IL 60619	<b>Tank Capacity</b>	5,000
<b>County</b>	Cook	<b>Tank Install Date</b>	6/29/2000
<b>Contact Name</b>	Hussain Yafai	<b>Current Product on File</b>	Diesel Fuel
<b>Phone Number</b>	(718) 844-0990	<b>Newly Reported Product</b>	E85

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	xerxes tanks.pdf	Existing

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron LCX	Manufacturer Approval	NOV LCX pipe and fittings .pdf	Existing & 5 lf. replaced per permit
Shear Valve	OPW, 10P-0152E85	Manufacturer Approval	opw all products.pdf	Replaced per permit

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling, TSM-4245	Manufacturer Approval	FFS-0691+UL+2447+Product+Description+Datasheet.pdf	Replaced per permit
Single Wall UDC Sump	Westerrn Fiberglass	Manufacturer Approval	Western-Fiberglass sumps. pdf	Existing

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root TLS 300	Veeder Root, 846391-407	Manufacturer Approval	veeder root probes.pdf	REplaced per permit

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	Franklin MLD AG.pdf	Replaced per permit

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	Existing

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling, Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	Replaced per permit

## Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	Replaced per permit
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	Wayne Ovation EB23.pdf	Replaced
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	Replaced
Hose	Continental, Futura Etan-all	Manufacturer Approval	Flexsteel® Futura™ Ethanol-ALL™ Dispensing Industrial Hoses _ Continental Industry.pdf	Replaced

## Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

## Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Correspondence Contact

**Submitter Name** Ed Angell

**Job Title** Project Manager

**Company** B&K Equipment Company

**Phone Number** (708) 474-3344

**Email** ed@bkequip.com

**Contractor License #** IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.